

> Letter of Conformity

(Confirmation of Quality Assurance)

Rev. 00-15.03.2022 for year 2022

We herewith confirm that all SEMIKRON products of the range/product
SEMIPACK

are taken to the following tests:

- VRRM, VDRM (25°C; $\geq 110^\circ\text{C}$)*
- VT, VF (25°C; IT, IF $\approx 3 \times \text{ITAV}$, IFAV)**
- VGT, IGT (25°C)
- IGD ($\geq 110^\circ\text{C}$)*
- IH, IL (25°C)***
- Visol
- visual/optical inspection

* VRRM, VDRM and IGD at T_{vjmax} are ensured.

** VT, VF for SEMIPACK6 is measured at T_{vjmax} .

*** IH, IL are verified either at chip level or module level.

We confirm that the technical data, specified in the actual valid SEMIKRON data sheet, are kept.

Place/Date

Quality OPM
(Operations Modules/Systems)

Product Manager

Nuremberg/15.03.2022


Peter Abel/Maurilio Muscolino
Rastislav Kosiba